

Project Manual

2nd floor dehumidification

January 21,2021

Champlain Valley School District

Hinesburg Community School

Project Manual

2nd floor dehumidification

Hinesburg Community School

10888 Rte. 116 Hinesburg, VT. 05461

January 21, 2021

Includes:

- **Invitation to Bid**
- **Bid Form**
- **Project Specifications/Plans**

OWNER:

Contact: Tim Peet
(802) 482-6297, tpeet@cvsdvt.org

Contract Administrator:

Champlain Valley School District
5420 Shelburne Road, Suite 300
Shelburne, Vermont 05482
Contact: Jeanne Jensen, Chief Operations Officer
802-383-1234
FAX: 802-383-1242

CHAMPLAIN VALLEY SCHOOL DISTRICT
Hinesburg Community School
2nd floor dehumidification
Invitation to Submit Proposals

The Champlain Valley School District invites you to submit a proposal for Replacing the existing air handler known as AHU-2 with a new unit that provides dehumidification at the Hinesburg Community School. The project outline and specifications for the above referenced project are contained in this packet.

BID INFORMATION

Bid Due Date is February 24, 2021 at 2pm. **Please email bids to Tim Peet tpeet@cvsdvt.org and Chris Giard cgiard@cvsdvt.org** This is a public bid opening.

Direct Quotation and All Bid Correspondence To:

Jeanne Jensen, Chief Operations Officer
Champlain Valley School District
5420 Shelburne Road, Suite 300
Shelburne, VT 05482
802-383-1234
802-383-1242 (FAX)

Point of Contact at Site:

Tim Peet
Hinesburg Community School
10888 Rte. 116
Hinesburg, Vt. 05461
(802)482-6297
(802)482-2003 (fax)

Questions should be directed to Jeanne Jensen and concurrently copied to Tim Peet by facsimile or in writing. Answers to questions will be provided via facsimile or in writing and conveyed to all bidders.

CONTRACT AWARD

The contract award will be made on the basis of timeliness, manpower and equipment availability, responsiveness to the bid requirements, and the cost of work. The owner reserves the right to reject any or all bids, to waive any informality in any bid, and generally take such action as shall be in their best interest.

PROJECT SCHEDULE

Project Milestones:

- | | |
|---|--------------------------|
| ● Invitation to Bid | January 21, 2021 |
| ● Site Walk-Thru | February 10, 2021 at 9am |
| ● Bids Due | February 24, 2021 |
| ● Award Contract | March 17, 2021 |
| ● Site Available for Construction Start | June 21, 2021 |
| ● Project Complete, No Later Than | August 19, 2021 |

Walk through with willing contractors will follow the state of VT COVID 19 guidelines. Social distancing and mask are required.

STATE and LOCAL TAXES

This project is tax exempt. State and local taxes applicable to the project will not be included in the bid.

BID REQUIREMENTS

1. The Bid Form is included in this manual and shall be completed in total and signed by an authorized representative of the Bidder.
2. The bid shall remain valid for forty-five (60) days from the Bid Due Date.
3. The Quotation shall be lump sum, all-inclusive, FOB job site, including any and all costs for labor, materials and equipment.
4. When a particular make or trade name is specified it is meant to establish a quality standard and is not intended to eliminate a competing manufacturer of equal or greater quality. Manufacturer other than those listed in the specifications will not be accepted unless product information is submitted to the Owner for approval a minimum of seven (7) business days prior to the bid date.
5. All materials provided will be Asbestos Free and a letter to the owner will be provided at the completion of the project that states all materials used were free of Asbestos containing materials.
6. Exclusions to any of the work shall be clearly stated with the bid.
7. Bidders shall include a completed Form W-9 with bid
8. The cost of a 100% Payment and Performance Bond is required to be included and itemized in the bid. A letter of surety from the bonding agent is to be attached to the Bid Form. Reimbursement for this Bond shall be based on the actual invoiced amount from the bonding agent; however, the reimbursement will in no case exceed the amount stated on the bid form. Owner may choose to waive this requirement prior to awarding the bid.

MISCELLANEOUS INCLUSIONS

1. All work must be in strict accordance with local, state and federal codes and requirements.
2. The Owner will not be responsible for costs incurred by overtime work required to meet the aforementioned schedule.
3. Contractor will insure the protection of Owner's property during construction. Contractor will protect materials brought on to the school grounds from damage and the elements.
4. In-building storage of material will / will not be allowed as designated by the owner. All trash and leftover materials to be hauled away at contractor's expense.
5. **No Smoking/ Vaping permitted on school grounds or any other tobacco products are permitted.**
6. Job site clean up on a daily basis to a dumpster provided by the Contractor is part of the scope of work associated with this project. In the event that the contractor does not adequately perform clean up of its materials, then the work will be provided by the Owner at a cost of \$50.00/hour for each individual employed in the clean up process. The cost of it will be deducted from the contractor's contract amount.
7. Contractor will provide all equipment necessary for this project. It is not anticipated that a separate contractor will be needed to complete this work. If the bidder feels additional subcontractors of any kind are necessary, these subcontracts should be noted in the exclusions/qualifications section of the bid form.

TERMS of PAYMENT

1. The Board of School Directors will make payment to the successful Bidder within twenty (20) working days following approval of the Payment Requisition by the Owner and the Owner's representative.
2. Owner will withhold 10% of the successful Bidder's requisitioned amount until work is satisfactorily completed and accepted by the Owner.

WORK LOAD

1. The bidders will state their current workload (i.e. jobs in progress at the time of bid) and will clearly indicate their ability (by statement) to perform in accordance with the schedule enclosed herein

DISCREPANCIES

In the event of conflicts, discrepancies, errors, omissions or work shown but not specified or vice versa, it shall be brought to the attention of the Owner, in writing, requesting clarification in the matter.

Irregularities in the documents shall not constitute basis for a claim since the work shall be considered whole and complete as contained in the documents.

Statements in the Invitation to Bid take precedence over the specifications.

The project consists of:

Replacing the existing air handler known as AHU-2 with a new DAIKIN Model # DPS020A as per the attached scope of work.

Scope of Work:

The scope of work to be incorporated with this project includes, but is not limited to the following:

1. Remove and dispose of the 1 existing 1998 air handler identified as AHU-2
2. REWORK AHU-2 controls to accommodate new unit controls and functions. Reuse control wiring and conduit as appropriate, add new as required.
3. Furnish & install NEW AHU-2, in the same location as the unit removed and reconnect ductwork to the return air and supply air ductwork. CURB ADAPTER required to match new unit duct connections to existing duct at roof deck.
4. Supply integral disconnect switch
5. Access existing ductwork on supply and return from inside (above corridor ceiling) as necessary for new unit connections.
6. Furnish and install all new controls for the new rooftop unit to meet detailed sequences of operation. Upgrade the building's FMCS graphics screens to reflect new unit and all required I/O per sequence of operation.
7. Replace duct insulation removed to make duct reconnections.
8. Start-up units and complete startup documentation. TAB for all supply & return to 75% of 1998 design values, calibrate unit AFS, report unit data
9. Provide Commissioning support with Engineer verifying installation and operation to these contract documents.
10. Training & Documentation. Provide training on maintenance of new roof top unit.
11. Provide O&M Manuals for roof top unit and controls. Documentation to include AS-BUILT CONTROL Drawings and SEQUENCES OF OPERATION for all equipment

See attached documents for a detailed scope of work.

Exclusions:

- 1) Disconnecting power from existing AHU-2
- 2) Upgrade electrical service from the breaker panel to disconnect switch on the new unit.
- 3) Removal and installation of any hard ceiling if required.

NOTE:

- 1) The contractor shall notify the owner five (5) days prior to the commencement of work.
- 2) The contractor shall be responsible for initiating, maintaining and supervising all O.S.H.A. safety precautions in connection with this project.
- 3) Prior to the commencement of this project, the contractor shall be familiar with all safety regulations and practices applicable. No additional payments will be made for equipment and procedures necessitated by these safety precautions.
- 4) Certificate of Insurance acceptable to the Owner shall be filed with the Owner prior to commencement of work.
- 5) Contractor will warrant material and workmanship for a minimum of one year,

CHAMPLAIN VALLEY SCHOOL DISTRICT
Hinesburg Community School
2nd floor dehumidification

BID FORM

Date _____

Proposal of

Hereinafter called “Bidder”, a (corporation) (partnership) (circle one)

Of the State of _____

To: Champlain Valley School District;

The Bidder, in compliance with the Invitation for Bids for the proposed Replacing existing air handler known as AHU-2 with a new unit that provides dehumidification at the Hinesburg Community School, having examined the Specifications with related documents and the site of the proposed work, and being familiar with all of the conditions surrounding the construction of the proposed project including the availability of materials and labor, hereby proposes to furnish all labor, materials, and supplies necessary to satisfactorily complete the in accordance with the Contract Documents, within the time set for the therein, and at the prices stated below. These prices are to cover all expenses incurred in performing the work required under the Contract Documents, of which this proposal is a part. The Bidder hereby agrees to commence work under this Contract after _____ on a date to be specified in written notice by the bidder to the OWNER and to reach final completion of the project, by _____.

Bid Form (cont.)

The undersigned, as Bidder, declare the only person or parties interested in this Proposal as principals are those named herein; that this Proposal is made without collusion with any other firm, and the undersigned will take in full payment, therefore, the following Base, Bond, Warranty, Unit and Alternate Prices, to wit:

Base Bid Amount

_____ Dollars

Base Bid Written Amount

_____ Dollars

Base Bid Numerical Amount

Alternates (if required)

_____ Dollars

Base Bid Written Amount

_____ Dollars

Base Bid Numerical Amount

Bonding Costs (Bond Cost is an ADD to Total)

We will provide a 100% Payment and Performance Bond, as indicated in the attached letter from our bonding agent. The cost will be invoiced to us from our bonding agent, and will in no case exceed the amount designated below:

_____ Dollars

Bond Cost in Numbers

_____ Dollars

Bond Cost Written Amount

Warranty

Warrantee the installation for 1 year from date of Cx Verification the UPGRADED system is fully functional and approved for owner turnover (ALL ISSUES LOG ITEMS CLEARED!)

Unit Prices

We propose to provide additional labor and materials for the following work based upon the following unit prices. The Owner and Owner's representative shall approve the necessity of these additional materials prior to their procurement, and the installed quantities shall be certified by the Owner's

Contractor Exclusions, Additional Subcontracts, and/or receipt of Addendum

Use the space below to list any exclusions, Additional Subcontractors required and/or receipt of Addendums issued by the Owner or Owner's Representative. Attach an additional page signed and dated if necessary.

Current Work and Proposed Schedule

We currently have _____ jobs scheduled for this summer.

Baring unforeseen circumstances, we proposed to have materials on site and begin work on _____ (Date)

Bidder Qualifications

The undersigned submits answers to the following questions to enable the Champlain Valley School District to judge his/her experience and ability in and facilities for the work proposed to be done.

The work, if awarded to you, will have the resident personal supervision of whom? State his/her (or their) special qualifications.

Describe equipment you propose to furnish. (a) Your own; (b) rented.

How many years has your organization been in business as a contractor under the name in which you propose to execute this contract?

Has your present organization ever failed to complete work awarded to it? If so, state when, where and why.

Bidder Acknowledge

The undersigned hereby certifies that he/she is able to furnish labor that can work in harmony with all other elements of labor employed on the work.

The undersigned hereby acknowledges that he/she has read this proposal in its entirety and understands and agrees to all provisions contained herein.

Respectfully submitted:

(Firm Name)

By _____
(Signature)

Firm Information

Contact Person: _____

Mailing Address _____

Phone Number _____

Fax Number _____

END of BID FORM